



Mob : 7970255060
9827878998

FIRE STOPPER

(FIRE SAFETY ENGINEER & CONTRACTOR)

Auth. Dealer Branded Companies (ISI Marked)
deals in : Fire Fighting Equipment & General Order Supplier

Report card

Date: 11/11/2025

This is to certify that we **M/s Fire Stopper** (Fire safety engineering & contractor) A 67, part B, Govindpuri Gwalior (M.P.) Has Refilling, Inspected and serviced the fire extinguisher for **M/s ACADEMIC HEIGHTS PUBLIC SCHOOL**

AB Road morena village karua

MORENA (M.P)

S.No.	Description	Capacity	Qty.	Date of refilling	Next due date of refilling
01	Refilling of ABC stored pressure type Fire Extinguisher	06 kg	08	11/11/2025	10/11/2026

Inspection of fire safety equipment checklist & summary:

M/s ACADEMIC HEIGHTS PUBLIC SCHOOL was surveyed for fire safety

Fire extinguishers have a crucial role in ensuring fire safety

Safe lives or at least help to minimize unnecessary costs or other losses.

The purpose of this survey was to identify significant fire safety issue which will be further

1 fire extinguisher is in fully charged and tagged

2 pressure gauges is in the green area

3 fire extinguisher tags are current

4 the tags expires one year from date of refilling

Fire extinguisher are working condition and fully charged

Thanks
Regards for m/s fire stopper



A67-B Govindpuri Gwalior – 474002 (M.P.) Contact: 7024103403

E-mail: firestopper009@gmail.com